

EtherCAT[®] Supplemental Manual

GF40 and GF80 Series Mass Flow Controllers & Meters

Essential Instructions

Read this page before proceeding!

Brooks Instrument designs, manufactures and tests its products to meet many national and international standards. Because these instruments are sophisticated technical products, you must properly install, use and maintain them to ensure they continue to operate within their normal specifications. The following instructions must be adhered to and integrated into your safety program when installing, using and maintaining Brooks Products.

- Read all instructions prior to installing, operating and servicing the product. If this instruction manual is not the correct manual, please see back cover for local sales office contact information. Save this instruction manual for future reference.
- If you do not understand any of the instructions, contact your Brooks Instrument representative for clarification.
- Follow all warnings, cautions and instructions marked on and supplied with the product.
- Inform and educate your personnel in the proper installation, operation and maintenance of the product.
- Install your equipment as specified in the installation instructions of the appropriate instruction manual and per applicable local and national codes. Connect all products to the proper electrical and pressure sources.
- To ensure proper performance, use qualified personnel to install, operate, update, program and maintain the product.
- When replacement parts are required, ensure that qualified people use replacement parts specified by Brooks Instrument.
- Unauthorized parts and procedures can affect the product's performance and place the safe operation of your process at risk. Look-alike substitutions may result in fire, electrical hazards or improper operation.
- Ensure that all equipment doors are closed and protective covers are in place, except when maintenance is being performed by qualified persons, to prevent electrical shock and personal injury.

ESD (Electrostatic Discharge)

CAUTION

This instrument contains electronic components that are susceptible to damage by electricity. Proper handling procedures must be observed during the removal, installation, or other handling of internal circuit boards or devices.

Handling Procedure:

1. Power to the unit must be removed.
2. Personnel must be grounded, via a wrist strap or other safe, suitable means before any printed circuit card or other internal device is installed, removed or adjusted.
3. Printed circuit cards must be transported in a conductive container. Boards must not be removed from protective enclosure until immediately before installation. Removed boards must immediately be placed in protective container for transport, storage or return to factory.

Comments:

This instrument is not unique in its content of ESD (electrostatic discharge) sensitive components. Most modern electronic designs contain components that utilize metal oxide technology (NMOS, SMOS, etc.). Experience has proven that even small amounts of static electricity can damage or destroy these devices. Damaged components, even though they appear to function properly, exhibit early failure.

Section 1 General Information

Introduction.....	5
-------------------	---

Section 2 Definition of Terms

Definition of Terms	6
---------------------------	---

Section 3 Before Starting

Background & Assumptions	7
Numbers	7

Section 4 Quick Start

Quick Start.....	8
Master Hardware	8
Physical Interfaces	8
Power Supply and Analog I/O	8
RUN and MOD LEDs.....	10
EtherCAT MFC Slave Hardware	10
EtherCAT Theory.....	11

Section 5 Slave Configuration

Introduction.....	16
Outputs (Master Side)	16
Inputs (Master Side).....	17
COE Online Attributes	18
Device Attributes	18
Flow Sensor.....	18
Flow Sensor Zero Adjust	19
Flow Sensor Status	20
Temperature Sensor.....	21
Temperature Sensor Status	22
Setpoint Controller	22
Setpoint Controller Status.....	23
Valve Actuator Attributes	24
Service Transfer Attributes	25
Calibration Object Attributes	26
Exceptions	27
Alarm and Warning Details.....	27
Exception Status.....	27

Warranty, Local Sales/Service Contact Information

Warranty, Local Sales/Service Contact Information	Back Cover
---	------------

Figures

4-1 EtherCAT Label on Cover	8
4-2 M8 Male Device Connector Pin Layout, Pin Side View.....	9
4-3 M8 Female Mating Cable	9
4-4 M8 Female Mating Cable Connector Pin Layout.....	9
5-1 Output PDOs	16
5-2 Input PDOs.....	17
5-3 Device Attributes	18
5-4 Flow Sensor Attributes	18
5-5 Flow Sensor Zero Adjust Attribute.....	19
5-6 Flow Sensor Status Attributes	20
5-7 Temperature Sensor Attributes	21
5-8 Temperature Sensor Status Attributes	22
5-9 Setpoint Controller Attributes	22
5-10 Setpoint Controller Status Attribute	23
5-11 Valve Actuator Attributes.....	24
5-12 Valve Actuator Status Attributes.....	25
5-13 Service Transfer Attributes.....	25
5-14 Calibration Object Attributes.....	26

Tables

4-1 Pin Labeling of M8 Male Device and Female Mating Cable Connector.....	9
4-2 Wire Labeling of M8 Female Mating Connector	10
4-3 M8 Female Mating Cable Part Numbers	10
4-4 RUN LED Specification	10
4-5 MOD LED Specification.....	10
5-1 Valve Override Values (vdOverride).....	28
5-2 Flow Data Units (fmUnits)	28
5-3 Temperature Data Units (tmUnits)	28
5-4 Setpoint Control Mode (fcControlMode).....	28
5-5 Valve Drive Data Units (vdUnits).....	28

Introduction

Many applications of Flow Controllers/Meters are moving to increasing use of automation. Automation comes in many forms: PLC's (Programmable Logic Controllers such as the Siemens S7 300/4000), DCS's (Distributed Control Systems, such as Emerson's Digital V), PC based solutions (National Instrument's Labview™) and Ethernet based field buses. Digital communications from these varied systems and the devices they measure and control, are a very effective means of not only accomplishing more effective and rapid system integration, but also providing greatly improved system diagnostics and maintainability. EtherCAT is an Ethernet based communication system and is known for its high cycle time and cost efficient cabling and master application solutions. Brooks Instrument now introduces the EtherCAT interface on its GF Series platform.

Definition of Terms

Abbreviation	Description
Byte	A Byte refers to 8 consecutive bits.
CoE	CANOpen over EtherCAT
CRC	Checksum
Cycle	A cycle is defined as the process of sending a command, waiting for a response, and processing it in order to be ready to send a new command.
EEPROM	Electrically Erasable Programmable Read-Only Memory.
ESC	EtherCAT Slave Controller
ESI	EtherCAT Slave Information file. (Device description in XML format)
EtherCAT	Ethernet for Control and Automation Technology
Frame	The transportation unit in a network, also known as a packet. (Contains a Header followed by the data to be sent).
Header	The Header is part of the Frame and contains all protocol defined constructs for addressing, size, etc.
LSB	Least Significant Bit
MAC	Media Access Control is responsible for address checking and is most often done in the hardware of a NIC.
Master	A Master is a unit which controls the Slaves, feeding them commands and receiving status reports in exchange.
MFC/MFM	Mass Flow Controller / Mass Flow Meter
MSB	Most Significant Bit
MTU	Maximum Transmission Unit. The maximum payload that a standard Ethernet Frame can hold. The MTU is set at 1500 bytes (Not considering the Header and Checksum).
NIC	Network Interface Controller. A hardware component that connects a computer to a network.
OSI Model	A standardized representation for how a communication system can be organized. (e.g., a protocol stack) The model is divided into layers, each responsible for a part of the communication.
PDO	Process Data Object
PDU	Protocol Data Unit. A Slave command
RO	Read Only
RT	Real-time. A system that adheres to strict timing demands.
RW	Read / Write
SDO	Service Data Object
SII	Slave Information Interface. Data stored on an EEPROM in the Slave, containing information about it and its operation.
Slave	A Slave is a unit (node) on the EtherCAT network (e.g., an MFC). The Slave is connected to a Master.
Stack	A synonym for the implementation of the layers of a protocol. (e.g., a Master)
Topology	The way a network (Master & Slaves) is connected. The overall layout. (e.g., Star, Tree, Line Topology)
WO	Write Only

Background & Assumptions

This manual is a supplement to the Brooks GF40/GF80 Series installation and operation manual. It is assumed that the owner of this EtherCAT MFC/ MFM is thoroughly familiar with the theory and operation of this device. If not, it is recommended that the owner read the installation and operation manual first before continuing with this supplement. This manual assumes basic knowledge and understanding of EtherCAT (its topology and its method of logically accessing the data or parameters contained within the device). This manual is not intended to be a replacement to the EtherCAT specifications. It is recommended but not required for the purposes of this manual, that the user obtains a copy of the EtherCAT specifications (www.ethercat.org). This manual does not make any assumptions about any particular manufacturer of equipment or custom software used by the user to communicate with the Brooks device, but assumes the user has thorough understanding of such equipment and any configuration software. Application Notes and FAQ's are available at the Brooks Instrument web site (www.BrooksInstrument.com).

Numbers

Numeric values used throughout this manual will be clearly denoted as to the base numeric system it represents. All hexadecimal numbers (base 16) will be prefixed with a 0x, like 0xA4. All binary numbers (base 2) will be suffixed with a b, like 1001b. All other numbers not annotated this way will be assumed decimal (base 10).

Quick Start

This section assumes the owner of the Digital Series device has a fully operational and trouble-free communications network with appropriate power supplies. This section also assumes that an EtherCAT master application is connected to the network capable of PDO and mailbox data communication. Both types of data communication modes are supported by the Brooks GF40/GF80 EtherCAT device

Master Hardware

Various companies provide EtherCAT master applications, e.g. TwinCAT from Beckhoff, or offer EtherCAT master stacks to develop a master application, e.g. Acontis. A PC can be used to run most EtherCAT master applications but needs dedicated Ethernet hardware to support the high cycle times and kernel mode operation of the master application, see www.beckhoff.com. Screenshot of master applications used in this manual are taken from the EtherCAT configurator tool or TwinCAT3® application from Beckhoff.

Physical Interfaces

The available physical interfaces on the EtherCAT device are listed below:

- 5 pin M8 threaded male connector for power and analog I/O, indicated by PWR
- IN and OUT ports with RJ45 connectors
- ZERO push button, refer to the GF40/80 Series installation and operation manual for more details
- 2.5mm female jack for RS485 diagnostics port indicated by DIAG, refer to the GF40/GF80 Series installation and operation manual for more details




Figure 4-1 EtherCAT Label on Cover

Power Supply and Analog I/O

Power needs to be supplied via the M8 connector. This connector also provides access to analog I/O signals, see Table 4-1.




Figure 4-2 M8 Male Device Connector Pin Layout, Pin Side View

Table 4-1 Pin Labeling of M8 Male Device and Female Mating Cable Connector

Pin Label	Function at Remote Connector
P_COM	Power Supply Common
+VPWR	Positive Power Supply Voltage
V_AUX_OUT	Flow Output 0-5V
AGND	Analog I/O Common
V_AUX_IN	Auxiliary Input 0-5/10V for Future Use

M8 mating cables can be purchased as a second line item, details given below.




Figure 4-3 M8 Female Mating Cable




Figure 4-4 M8 Female Mating Cable Connector Pin Layout

Table 4-2 Wire Labeling of M8 Female Mating Cable Connector

Wire Color	Wire Label	Function at Remote Connector
Blue	P_COM	Power Supply Common
Brown	+VPWR	Positive Power Supply Voltage
Black	V_AUX_OUT	Flow Output 0-5V
White	AGND	Analog I/O Common
Grey	V_AUX_IN	Auxiliary Input 0-5/10V for Future Use

Table 4-3 M8 Female Mating Cable Part Numbers

Supplier	Part Number	Description
Brooks Instrument	124X049AAA	M8 Mating Cable 2m
	124X050AAA	M8 Mating Cable 5m

RUN and MOD LEDs

The device supports a RUN and MOD LED to indicate the status of network communication and the device. The RUN LED will indicate the following:

Table 4-4 RUN LED Specification

Flash Code	Description
Off	The device is in state INIT
Rapid Flashing	About 3 times per second
Slow Flashing	About once per second
On	The device is in state OPERATIONAL
Flickering	The device is booting and has not yet entered the INIT state

The MOD LED will indicate the following:

Table 4-5 MOD LED Specification

Flash Code	Description
Flashing Red/Green	The device is in the Self-Test mode
Solid Green	All self-tests have passed. No faults have been detected
Flashing Red	A recovering alarm has been detected
Flashing Green	A recoverable warning has been detected
Solid Red	An unrecoverable fault has occurred

EtherCAT MFC Slave Hardware

The main parts of the EtherCAT MFC are:

- Standard Ethernet Physical Layer Components
- EtherCAT Slave Controller (ESC) and EEPROM (ESC configuration data and application specific data)
- For intelligent slaves with an application controller: Host controller

EtherCAT Theory



Ethernet for Control and Automation Technology

- Uses standard Ethernet hardware, Cat 5 cabling, and Network Interface Cards (NIC).
- Streamlines Ethernet communication at the hardware level.
- Data processing on Slave devices is handled “on-the-fly” via FPGA or ASIC, minimizing latency.
- Initial setup and configuration is required.

Frames (EtherCAT vs Ethernet)

Ethernet Header:

- Ether type 0x08A4 specifies EtherCAT

EtherCAT Header:

- Data Length: 11bits
- Reserved: 1bit
- Protocol type: 4bits (0x01 indicates CoE/Can over EtherCAT)

EtherCAT Data:


- 46 – 1496 bytes

Working Counter:

- 2 Bytes

CRC (Checksum):


- 4 Bytes



Speed

- The EtherCAT protocol reduces the addressing overhead by letting a Master communicate with all Slaves using a single frame, instead of one frame per device.
- This One Frame holds messages to any or all slaves on the network.

EtherCAT Examples



Analogy: Fast Train.

- “Train” (EtherCAT Frame) does not stop.
- Even when watching “Train” through narrow window one sees the entire “Train”
- “Car 27” (Sub-Telegram) has variable length. (46-1496 bytes)
- One can “extract” or “insert” single “persons” (Bits) or entire “groups” (Bytes) – even multiple groups per train... This is done without the train ever having to stop!
- An EtherCAT Master initially maps out the location and addresses of all of the slaves.
- The single EtherCAT Frame (the train) has instructions loaded on-board for some or all of the slaves.
- Only the instructions that are specifically addressed to a specific slave are delivered to that slave.



Another Example of the EtherCAT process...

- Each cubicle is an EtherCAT slave containing an engineer (a SLA58xx).
- Each engineer is told where to sit by its hardware address (Station ID).
- The Engineer is assigned specific tasks (by SDO's).
- The Boss (Master) identifies each engineer by first and last name, what they look like, and where exactly they are sitting.
- The Boss is the EtherCAT Master, sending instructions (PDO's) out to the engineers each morning and picking up their work at the end of the day.

EtherCAT Explained

1. EtherCAT Communication

- Each slave on the network has a unique address, set by hardware.
- Master/Slave configuration with the EtherCAT Master sending and requesting data from the Slave.
- Data not addressed to a particular slave are forwarded along to the network.
- Minimal processing time can provide cycle update rates of up to 32kHz.
- Network physical layout is limited only by the allowable lengths of CAT5 Ethernet cable, up to 100m.
- Increased noise immunity due to reliance on Ethernet physical components.

2. SDO's and PDO's

Data is moved along an EtherCAT network using two protocols: SDO's and PDO's

SDO: Service Data Object

- SDO's can be sent at any time... before, after or during real time operation of the network of the network
- As a result, SDO usage is typically only used for Network Setup Commands. PDO: Process

Data Object

- PDO's contain the raw operational data with minimal overhead and thus are used for real time processes, like motion and I/O control.
- PDO's can only be used once they have been mapped using SDO's.
- Mapping sets up which byte in each PDO goes to which memory address on the slave.

3. EtherCAT Master

- Can be software and or hardware configured to assemble, send and receive EtherCAT datagrams.
- Requires only standard Ethernet physical layer components for communications.
- Facilitates coordination between EtherCAT slaves, writing and receiving data from each slave in an EtherCAT frame.
- In motion control applications, the relevant data sent to the drives are profiling data.
- The data requested are position and input status.

4. EtherCAT Slave


- Reads and processes profiling data.
- Can be configured for multiple modes of operation.
- All slaves contain specific spaces in memory where data can be written

5. SDO vs PDO Summary

SDO	PDO
Transfer Confirmation	No Transfer Confirmation
Client/Server Model	Peer-to-peer Model
Device Configuration, PDO Mapping	High priority transfer of small amounts of Data.
Can be sent at any time	Can only be used after configuration using SDO's
Significant communication overhead	No additional protocol overhead.

6.The EtherCAT Slave State Machine

STATE	Allowed Communication
INIT	No User Communication
Pre-OP	SDO Communication Only
Safe-OP	SDO, PDO Communication Allowed Output PDO Info ignored
OP	SDO & PDO Communication Allowed



Incoming PDO	
Location	Function
X607A	Target Setpoint
X6060	Mode of Operation
X6040	Control Word

Outgoing PDO	
Location	Function
X6041	Status word
X6062	Setpoint Demand Value
X6061	Mode of Operation
X6064	Setpoint Actual Value
X60FD	Digital Input Status

Introduction

Based on the information provided by the EtherCAT Slave Information file (ESI, device description in XML format) and/ or the EEPROM, master applications are able to configure the EtherCAT network.

For the EtherCAT network configuration of the GF40/80 Series devices the following ESI file is provided on the Brooks website (www.BrooksInstrument.com):

- ‘Brooks GF04x.xml’ – GF40/80 Series Mass Flow Controller/Meter

Outputs (Master Side)

The request message, sent from master to slave, consists of the fields indicated in Figure 5-1, these fields will be described in the sections below.




Figure 5-1 Output PDOs

Index Number	Output PDO	Data Units	Description
0x1600:01 PDO index	Controller Setpoint	Specified by Setpoint Controller Data Units	Setpoint specified in the selected Data Units
0x1601:01 PDO index	Actuator Override	vdOverride Table 5-1 Valve Override Values (vdOverride)	Valve override

Inputs (Master Side)




Figure 5-2 Input PDOs

PDO Entry Index	Input PDO	Data Units	Description
0x6000:01	Sensor AI-MP (Flow, Real) 0x1A00	Specified by Flow Sensor Data Units	Flow specified in Flow Sensor Data Units
0x6020:01	Temperature (Real) 0x1A01	Specified by Temperature sensor Data Units	Temperature specified in Temperature Sensor Data Units
0x6040:01	Actuator Drive Value (Real) 0x1A02	%	Valve drive value
0x6030:01	Controller Setpoint (Real) 0x1A03	Specified by Setpoint Con-troller Data Units	Setpoint specified in Setpoint Controller Data Units
0x6000:02	Sensor AI-MF Flow Totalizer 0x1A04	cm3	Flow totalizer Value
0x6040:02	Actuator Override 0x1A05	vdOverride Table 5-1 Valve Override Valves (vdOverride)	Valve override
0xF800:03	Exception Status 0x1A09	bit mask	Summary of Alarm and Warning Detail
0x6F00:02	Alarm Detail 0x1A0A	bit mask	alarms
0x6F00:03	Warning Detail 0x1A0B	bit mask	warnings

COE Online Attributes

Device Attributes

Index	Name	Access	Example Values
1000	Device type	RO	0x00000000 (0)
1001	Error register	RO	0x00 (0)
1008	Device name	RO	GF_SA4x
1009	Hardware version	RO	A
100A	Software version	RO	1.14
1018:0	Identity	RO	> 4 <
1018:01	Vendor ID	RO	0x00000602 [1538]
1018:02	Product code	RO	0x000002D6 [726]
1018:03	Revision	RO	0x00000E01 [3585]
1018:04	Serial number	RO	0x482499FB [1210358267]
F901	Device Type [DmA1]	RO	MFC
F902	Standard Revision Level [DmA2]	RO	E54-0997
F903	Device Manuf. Identifier [DmA3]	RO	Brooks Instrument
F904	Manufacturer Model Num [DmA4]	RO	GF080CXXC
F907	Serial Number [DmA7]	RO	3F1316204001
F920	Device Configuration [DmA8]	RO	GF080CXXC-SA44860C-VXVZE5

Figure 5-3 Device Attributes

Flow Sensor

Index	Name	Access	Example Values
8000:0	AI Error Settings	RO	> 2 <
8000:01	sasAlarmEnable	RW	FALSE
8000:02	sasWarningEnable	RW	FALSE
8004:0	Sensor AI-MF Settings	RO	> 37 <
8004:08	Alarm Trip Point High	RW	
8004:09	Alarm Trip Point Low	RW	
8004:0B	Warning Trip Point Higher	RW	
8004:0C	Warning Trip Point Low	RW	
8004:21	Data Type	RO	0x00CA (202)
8004:22	Data Units	RW	0x1007 (4103)
8004:23	Alarm Setting Time	RW	0x0000 (0)
8004:24	Warning Setting Time	RW	0x0000 (0)
8004:25	Rest Flow Totalizer	RW	00 00 00 00 00 00 00 00

Figure 5-4 Flow Sensor Attributes

Flow Sensor Attributes	Data Type	Description
sasAlarmEnable 8000:01	Enable (1) Disable (0)	Enable/disable the high and low flow alarm
sasWarningEnable 8000:02	Enable (1) Disable (0)	Enable/disable the high and low flow warning
Alarm Trip Point High 8004:08	To be specified in selected flow data units	Flow alarm high limit
Alarm Trip Point Low 8004:09	To be specified in selected flow data units	Flow alarm low limit
Warning Trip Point Higher 8004:0B	To be specified in selected flow data units	Flow warning high limit
Warning Trip Point Low 8004:0C	To be specified in selected flow data units	Flow warning low limit
Data Type 8004:21	Real (202)	Data type is fixed to Real
Data Units 8004:22	fmDataUnits Table 5-2 Flow Data Units (fmDataUnits)	Flow data units
Alarm Setting Time 8004:23	Time:ms	Time in milliseconds that the alarm condition needs to be present before the alarm is raised
Warning Setting Time 8004:24	Time:ms	Time in milliseconds that the alarm condition needs to be present before the warning is raised
Rest Flow Totalizer 8004:25	0	Writing the value 0 to this attribute will reset the flowtotalizer

Flow Sensor Zero Adjust

Index	Name	Access	Example Values
B000:0	Service transfer	RO	> 5 <
B000:01	Perform Zero	WO	

Figure 5-5 Flow Sensor Zero Adjust Attribute

Service transfer attribute	Data Type	Description
Perform Zero B000:01	1	The flow sensor can be zero adjusted by writing a 1 to this attribute. Refer to the instruction manual for proper instructions.

Flow Sensor Status

Index	Name	Access	Example Values
A000:0	AI-MF Status	RO	> 33 <
A000:01	Status	RO	0x0002 (2)
A000:21	Zeroing Status	RO	0x0000 (0)

Figure 5-6 Flow Sensor Status Attributes

Flow sensor status attribute	Data Units	Description
Status A000:01	b00000001 (0x01) b00000010 (0x02) b00000100 (0x04) b00001000 (0x08)	Flow sensor status bit mask indication high and low flow alarms and warning High flow alarm Low flow alarm High flow warning Low flow warning
Zeroing Status A000:21 text	0 1	0 = idle 1 = zero adjust in progress

Temperature Sensor

Index	Name	Access	Example Values
8020:0	Temperature Error Settings	RO	> 2 <
8020:01	sasAlarmEnable	RW	FALSE
8020:02	sasWarningEnable	RW	FALSE
8024:0	Sensor Temperature Settings	RO	> 36 <
8024:08	Alarm Trip Point High	RW	
8024:09	Alarm Trip Point Low	RW	
8024:0B	Warning Trip Point High	RW	
8024:0C	Warning Trip Point Low	RW	
8024:21	Data Type	RO	0x00CA (202)
8024:22	Data Units	RW	0x1201 (4609)
8024:23	Alarm Setting Time	RW	0x00C9 (201)
8024:24	Warning Setting Time	RW	0x0065 (101)

Figure 5-7 Temperature Sensor Attributes

Flow sensor status attribute	Data Units	Description
sasAlarmEnable 8020:01	Enable (1) Disable (0)	Enable/disable the high and low temperature alarm
sasWarningEnable 8020:02	Enable (1) Disable (0)	Enable/disable the high and low temperature warning
Alarm Trip Point High 8024:08	To be specified in selectedtempera- ture data units	Temperature alarm high limit
Alarm Trip Point Low 8024:09		Temperature alarm low limit
Warning Trip Point High 8024:0B		Temperature warning high limit
Warning Trip Point Low 8024:0C		Temperature warning low limit
Data Type 8024:21		Data tupe is fixed to Real
Data Units 8024:22	tmDataUnits Table 5-3 Temperature Data Units (tmDataUnits)	Temperature data units
Alarm Setting Time 8024:23	Time:ms	Time in milliseconds that the alam condition needs to be present before the alarm is raised
Warning Setting Time 8024:24	Time:ms	Time in milliseconds that the wawrning condition needs to be present before the alarm is raised

Temperature Sensor Status

Index	Name	Access	Example Values
A020:0	Temperature Status	RO	> 1 <
A020:01	Status	RW	0x0000 (0)

Figure 5-8 Temperature Sensor Status Attribute

Temperature sensor status attributes	Data Units	Description
Status A020:01	b00000001 (0x01) b00000010 (0x02) b00000100 (0x04) b00001000 (0x08)	Temperature sensor status bit mask indicating high and low flow alarms and warnings High temperature alarm Low temperature alarm High temperature warning Low temperature warning

Setpoint Controller

Index	Name	Access	Example Values
8030:0	Controller Error Settings	RO	> 2 <
8030:01	sasAlarmEnable	RW	FALSE
8030:02	sasWarningEnable	RW	FALSE
8033:0	Sensor Controller Settings	RO	> 36 <
8033:01	Alarm Settle Time	RW	0x0000 (0)
8033:02	Alarm Error Band	RW	
8033:03	Warning Settle Time	RW	0x0000 (0)
8033:04	Warning Error Band	RW	
8033:21	Data Type	RO	0x00CA (202)
8033:22	Data Units	RW	0x1007 (4103)
8033:23	Control Mode	RW	0x0000 (0)
8033:24	Ramp Time	RW	0x0000 (0)

Figure 5-9 Setpoint Controller Attributes

Setpoint controller attribute	Data Units	Description
sasAlarmEnable 8030:01	Enable (1) Disable (0)	Enable/disable the setpoint error band alarm
sasWarningEnable 8030:02	Enable (1) Disable (0)	Enable/disable the setpoint error band warning
Alarm Settling Time 8033:01	Time:ms	Time in milliseconds that the alarm condition needs to be present before the alarm is raised
Alarm Error Band 8033:02	To be specified in selected data units	Setpoint alarm error band
Warning Settling Time 8033:03	Time:ms	Time in milliseconds that the warning condition needs to be present before the warning is raised
Warning Error Band 8033:04	To be specified in selected data units	Setpoint controller data units
Data Type 8033:21	Real (202)	Data type is fixed to Real
Data Units 8033:22	fmDataUnits Table 5-2 Flow Data Units (fmDataUnits)	Setpoint controller data units
Control Mode 8033:23	fcControlMode Table 5-4 Setpoint Control Mode (fcControlMode)	The setpoint control is fixed to the digital EtherCAT interface (future enhancement: analog setpoint source)
Ramp Time 8033:24	Time:ms	Time in milliseconds to reach a newly configured setpoint

Setpoint Controller Status

Index	Name	Access	Example Value
A030:0	Controller Status	RO	> 1 <
A030:01	Status	RW	0x0000 (0)

Figure 5-10 Setpoint Controller Status Attribute

Setpoint controller status attributes	Data Units	Description
Status A030:01	b00000001 (0x01) b00000010 (0x02)	Setpoint controller status bit mask Setpoint error band alarm Setpoint error band warning

Valve Actuator Attributes

Index	Name	Access	Example Values
8040:0	Actuator Error Settings	RO	> 2 <
8040:01	sasAlarmEnable	RW	FALSE
8040:02	sasWarningEnable	RW	FALSE
8044:0	Sensor Actuator Settings	RO	> 40 <
8044:21	Data Type	RO	0x00CA (202)
8044:22	Data Units	RW	0x1007 (4103)
8044:23	Alarm Trip Point High	RW	
8044:24	Alarm Trip Point Low	RW	
8044:26	Warning Trip Point High	RW	
8044:27	Warning Trip Point Low	RW	

Figure 5-11 Valve Actuator Attributes

Setpoint controller attribute	Data Units	Description
sasAlarmEnable 8040:01	Enable (1) Disable (0)	Enable/disable the setpoint error band alarm
sasWarningEnable 8040:02	Enable (1) Disable (0)	Enable/disable the setpoint error band warning
Data Type 8044:21	Real (202)	Data type is fixed to Real
Data Units 8044:22	vdDataUnits Table 5-5 Valve Drive Data Units (vdDataUnits)	Valve drive data units, fixed to percent (4103))
Alarm Trip Point high 8044:23	To be specified in selected valve drive data units	Valve drive alarm high limit
Alarm Trip Point low 8044:24	To be specified in selected valve drive data units	Valve drive alarm low limit
Warning Trip Point High 8044:26	To be specified in selected valve drive data units	Valve drive warning high limit
Warning Trip Point Low 8044:27	To be specified in selected valve drive data units	Valve drive warning low limit

Index	Name	Access	Example Value
A040:0	Actuator Status	RO	> 1 <
A040:01	Status	RW	0x0000 (0)

Figure 5-12 Valve Actuator Status Attributes

Valve Acuator Status Attributes	Data Units	Description
Status A0040:01	b00000001 (0x01) b00000010 (0x02) b00000100 (0x04) b00001000 (0x08)	Valve acuator status bit mask indication high and low valve drive alarms and warnings High valve drive alarm Low valve drive alarm High valve drive warning Low valve drive warning

Service Transfer Attributes

Index	Name	Access	Example Values
B000:0	Service transfer	RO	> 5 <
B000:01	Perform Zero	WO	
B000:03	Select Gas Table	RW	0x0001 (1)
B000:04	Full Scale Range	RO	
B000:05	Full Scale Range Units	RO	0x1400 (5120)

Figure 5-13 Service Transfer Attributes

Service Transfer Attribute	Data Units	Description
Perform Zero B000:01		Refer to Section 5.3.2.1 Flow Sensor Zero Adjust
Select Gas Table B000:03	1..6	Selected process gas page
Full Scale Range B000:04	Real	Full scale range being the flow at 100% setpoint
Full Scale Range Units B000:05	Table 5-2 Flow Data Units (fmDataUnits)	Data unit of the full scale range

Calibration Object Attributes

Index	Name	Access	Example Description
F880:0	Calibration Object	RO	> 5 <
F880:01	Last Calibration Date (SacA1)	RO	05302011
F880:02	Next Calibration Due Date (SacA2)	RO	05292012
F880:05	Run Hours (SacA5)	RO	0x00000000 (0)

Figure 5-14 Calibration Object Attributes

Calibration Object Attributes	Data Units	Description
Lat Calibration Date F880:01	Date	Date at which the device was calibrated
Next Calibration Due Date F880:02	Date	Date at which the device needs to be recalibrated
Run Hours F880:05	Time:hours	Time that the device has observed flow in the range of 0-100%

Exceptions

Alarm and Warning Details

The device, flow, temperature, setpoint controller and valve actuator related exceptions are collected in the alarm (F301Alarms) and (F401 warnings) warnings (8 bytes) detail byte sequences. The bitmasks are shown below.

	Byte nr	Bit 7	Bit 6	Bit 5	Bit 4	Bit 3	Bit 2	Bit 1	Bit 0	TwinCat hex values
Common Exception Detail Size	0	0	0	0	0	0	0	1	0	02
Common Exception Detail 1st byte	1	0	0	0	0	EEPROM	0	0	Internal Diagnostic	00, 01, 09
Common Exception Detail 2nd byte	2	0	0	0	0	0	Power supply output	0	0	00, 04
Device Exception Detail Size	3	0	0	0	0	0	0	0	1	01
Common Exception Detail 1st byte	4	0	0	Valve alarm high	Valve alarm low	Flow control alarm	Flow alarm high	Flow alarm low	Flow sensor reading not valid	00 to 3F
Manuf. Exception Detail Size	5	0	0	0	0	0	0	1	0	02
Manuf. Exception Detail 1st byte	6	0	0	0	0	Temp alarm high	Temp alarm low	0	0	00,08, 0C
Manuf. Exception Detail 2nd byte	7	0	0	0	0	0	0	0	0	00

Exception Status

The exception status is a one byte summary of the alarm and warning details.

	Bit 7	Bit 6	Bit 5	Bit 4	Bit 3	Bit 2	Bit 1	Bit 0
Exception Status F800:03 (1 byte)	0	Manuf. specific warning	Device specific warning	Common exception warning	0	Manuf. specific alarm	Device specific alarm	Common exception alarm

Value	Description
0	Normal
1	Off
2	Purge

Table 5-1 Valve Override Values (vdOverride)

Value	Description
4103	Percent
5120	SCCM
5121	SLM

Table 5-2 Flow Data Units (fmDataUnits)

Value	Description
4608	Celsius
4609	Fahrenheit
4610	Kelvin
4611	Rankine

Table 5-3 Temperature Data Units (tmDataUnits)

Value	Description
0	Digital
128	Analog (future)

Table 5-4 Setpoint Control Mode (fcControlMode)

Value	Description
4103	Percent

Table 5-5 Valve Drive Data Units (vdDataUnits)

LIMITED WARRANTY

Visit www.BrooksInstrument.com for the terms and conditions of our limited warranty.

BROOKS SERVICE AND SUPPORT

Brooks is committed to assuring all of our customers receive the ideal flow solution for their application, along with outstanding service and support to back it up. We operate first class repair facilities located around the world to provide rapid response and support. Each location utilizes primary standard calibration equipment to ensure accuracy and reliability for repairs and recalibration and is certified by our local Weights and Measures Authorities and traceable to the relevant International Standards.

Visit www.BrooksInstrument.com to locate the service location nearest to you.

START-UP SERVICE AND IN-SITU CALIBRATION

Brooks Instrument can provide start-up service prior to operation when required.

For some process applications, where ISO-9001 Quality Certification is important, it is mandatory to verify and/or (re)calibrate the products periodically. In many cases this service can be provided under in-situ conditions, and the results will be traceable to the relevant international quality standards.

SEMINARS AND TRAINING

Brooks Instrument can provide seminars and dedicated training to engineers, end users and maintenance persons.

Please contact your nearest sales representative for more details.

Due to Brooks Instrument's commitment to continuous improvement of our products, all specifications are subject to change without notice.

TRADEMARKS

Brooks, Brooks Service Tool and Quantim are trademarks of Brooks Instrument, LLC
All other trademarks are the property of their respective owners.



EtherCAT-Manual-GF40-GF80-EN/541B170AAG/2021-12

Global Headquarters

Brooks Instrument
407 West Vine Street
Hatfield, PA
19440-0903 USA

Toll-Free (USA): 888-554-FLOW
T: 215-362-3500

BrooksAM@BrooksInstrument.com

A list of all Brooks Instrument locations and contact details can be found at www.BrooksInstrument.com

© Copyright 2024 Brooks Instrument, LLC All rights reserved. Printed in U.S.A.

BROOKS[®]
INSTRUMENT
Beyond Measure